From:	Tim Girmscheid
Cc:	Quincy Bejster; Kristy De Boer; Theodora Anderson; Josue Pasillas
Bcc:	
Subject:	RE: Request for Quotes: Barrier Fence Replacements CLARIFICATION
Date:	Wednesday, February 17, 2021 3:13:00 PM
Attachments:	image003.png image005.png

Dear Prospective Contractor:

Since the snow is making it difficult to access the existing fences, we are providing the snapshots of the fabricating, hardware and install. Disregard the reference to 6’ spacing. We are using 8’ spacing for this project. Let me know if you have any questions. Thanks.

4x10 Standard Ground Contact Pressure Treated beveled rail.

4x4 Standard Ground Contact Pressure treated beveled rail.

6ft. o.c. Spacing 8x8 Heavy Ground Contact UC4B IDOT Spec Post. Holes 42" d x 15" min dia set in concrete. Apprx. 36" above grade beveled tops.



Hex Bolts, Hot dipped galvanized steel, 5/8"x11x11", including hot dipped galv. steel hex nuts and flat washers.

WAUKEGAN PARK DISTRICT



Tim Girmscheid, CPRP
Manager of Planning Services
Waukegan Park District
2211 Ernie Krueger Circle
Waukegan, IL 60087
847-360-4755 Office
847-561-1379 Cell
tgirmscheid@waukego anparks.org

Leaving a Legacy Greater Than Our Inheritance

From: Tim Girmscheid
Sent: Tuesday, February 16, 2021 10:53 AM
Cc: Quincy Bejster <qbejster@waukeganparks.org>; Kristy De Boer <kdeboer@waukeganparks.org>; Theodora Anderson <tanderson@waukeganparks.org>; Josue Pasillas <jpasillas@waukeganparks.org>
Subject: Request for Quotes: Barrier Fence Replacements CLARIFICATION

Dear Prospective Contractor:

The following grade of lumber is to be utilized for this project. Let me know if you have any questions. Thanks.

- 8” x 8” posts. Heavy Ground Contact UC4B IDOT Spec
- Top rail 4” x 10” – Standard Ground Contact Pressure Treated
- Bottom rail 4” x 4”. Standard Ground Contact Pressure Treated

Tim Girmscheid, CPRP
Manager of Planning Services

Waukegan Park District
2211 Ernie Krueger Circle
Waukegan, IL 60087
847-360-4755 Office
847-561-1379 Cell
tgirmscheid@waukeganparks.org

Leaving a Legacy Greater Than Our Inheritance

From: Tim Girmscheid
Sent: Wednesday, February 10, 2021 2:56 PM
Cc: Kristy De Boer <kdeboer@waukeganparks.org>; Josue Pasillas <jpasillas@waukeganparks.org>; Theodora Anderson <tanderson@waukeganparks.org>; Quincy Bejster <qbejster@waukeganparks.org>
Subject: Request for Quotes: Barrier Fence Replacements

Dear Prospective Contractor:

The Waukegan Park District is accepting quotes for:

2021 BARRIER FENCE REPLACEMENTS

Quotes are due on Wednesday, February 24, 2021 by 12:00 PM. via email to
tgirmscheid@waukeganparks.org
or to the Parks Maintenance Facility located at 2211 Ernie Krueger Circle, Waukegan, IL 60087.

We appreciate your quoting on the attached item and welcome the opportunity to do business with you.

If you have any questions, please contact me at 847-360-4755 or by email at
tgirmscheid@waukeganparks.org

Please note the Work of this Project is subject to the Illinois Prevailing Wage Act, 820 ILCS 130/0.01 et seq. A
prevailing wage determination has been made by the Park District, which is the same as that determined by
the Illinois Department of Labor for public works projects in Lake County. The successful contractor will also
provide a certificate of insurance naming the Waukegan Park District as the certificate holder and as additional
insured.

Sincerely,

Tim Girmscheid, CPRP
Manager of Planning Services
Waukegan Park District
2211 Ernie Krueger Circle
Waukegan, IL 60087
847-360-4755 Office

847-561-1379 Cell
tgirmscheid@waukeganparks.org

Leaving a Legacy Greater Than Our Inheritance