

WAUKEGAN PARK DISTRICT

ADDENDUM #1

To: All Bidders

From: Kristy De Boer, Park Planner

Re: Addendum #1

2017 Adelphi, Country Lane, and Washington Parks Concrete Installation
Bids Due on Tuesday, August 15, 2017 at 1:30 p.m.

Date: August 8, 2017

PLEASE MAKE NOTE OF THE CHANGES AND CLARIFICATIONS:

1. Clarification:

Contractor is to install outcropping stones to create steps in two areas as shown on plan. Pictures of the stone are on the following page.

2. Clarification:

Adelphi Park sidewalk is to be excavated and prepared by the contractor. Contractor to haul spoils off-site. Disposal of spoils will be allowed at our Callahan Park site at no cost to the contractor.

3. Clarification:

Concrete curbing at Washington Park and Country Lane Park will be excavated by Park District prior to work beginning. Contractor will need to make minor grade adjustments when laying out the curbing forms.

4. Change:

8" CMP culvert pipe with flared ends will be used in place of RCP culvert pipe with flared ends.

End of Addendum #1

BIDDERS ARE TO ACKNOWLEDGE RECEIPT OF ADDENDUM #1.

PLEASE FAX BACK TO WAUKEGAN PARK DISTRICT, PARKS DEPARTMENT AT 847-244-7345 OR EMAIL TO KDEBOER@WAUKEGANPARKS.ORG. ALSO, PLEASE INCLUDE AN EXECUTED COPY OF THIS ADDENDUM AND NOTE RECEIPT OF THIS ADDENDUM IN YOUR BID PROPOSAL.

ADDENDUM #1 RECEIVED:

SIGNED: _____

DATE: _____

COMPANY: _____

Thank you.

WAUKEGAN PARK DISTRICT

