WAUKEGAN PARK DISTRICT

ADDENDUM #1

To: All Bidders

From: Tim Girmscheid, Manager of Planning Services

Re: Addendum #1

2017 Field House at Hinkston Park LED LightingBids Due on Wednesday, July 19, 2017 at 11:30 a.m.

Date: July 14, 2017

PLEASE MAKE NOTE OF THE CHANGES AND CLARIFICATIONS: USE ATTACHED PRICE SHEET

1. Change:

Original electrical drawings indicated a three wire grounding NEMA L9-20 twist lock plug and receptacle were used at each light. Sheet note #1 incorrectly indicates existing twist lock plugs and receptacles are three wire grounding NEMA L9-20 and that pendant rewiring will be required. Existing plug and receptacle are five wire grounding NEMA L23-20 twist locks. Rewiring inside existing pendant is not required. Circuits will need to be adjusted in the junction box at the deck per the new plan.

2. Change:

Electrical contractor to provide an additional alternate bid #3 price for type A3 and B3 lights. Type A3 light shall be Lithonia JHBL-30000LM-ACL-WD-120-GZ10-40K-80CRI-SF-WGX-DWHXD-HCX. Type B3 light with emergency battery pack shall be Lithonia JHBL-30000LM-ACL-WD-120-GZ10-40K-80CRI-SF-BSL722C-WGX-DWHXD-HCX. Include safety cable. Add conduit nipple and coupling to adjust height of hook so bottom of light is at approximately the same height as the existing light fixtures.

3. Change:

Electrical contractor to provide additional alternate bids #4 thru #7 for completing work at night instead of during the day.

Alternate bids are as follows:

Alternate bid #4: additional cost to install base bid type A and B lights during a night shift. Alternate bid #5: additional cost to install base bid type A1 and B1 lights during a night shift. Alternate bid #6: additional cost to install base bid type A2 and B2 lights during a night shift. Alternate bid #7: additional cost to install base bid type A3 and B3 lights during a night shift. Gym available from 10 p.m. to 6 a.m. or later. Up to two courts may be worked on during the day until 4 p.m. By 4 p.m. all courts need to be operational.

4. Change:

Construction completion date extended to November 3rd.

Fnd of Addendum #1

BID ADDENDUM #1 PRICES: 2017 FIELD HOUSE AT HINKSTON PARK LED LIGHTING

4.06 BID PRICES

For completion of all Work shown on the Drawings and Specifications, the Bidder agrees to perform all Work for the following sums:

A.	• • • • • • • • • • • • • • • • • • • •	ight Fixture Schedule on Sheet E4 (Guaranteed Maximum Price)	OOLLARS
		 \$	JOELANS
B.	Alternate #1 Bid Price: Type A1/	/B1 from Light Fixture Schedule on Sheet E4 (Guaranteed Maximun	n Price) DOLLARS
	•	\$	
C.		/B2 from Light Fixture Schedule on Sheet E4 (Guaranteed Maximun	n Price) DOLLARS
	\$	\$	
D.		/B3 Specified in Bid Addendum #1 (Guaranteed Maximum Price)	OOLLARS
	\$	\$	
Ε.	Maximum Price)	st to install base bid type A and B lights during a night shift. (Guara	nteed
	5. TOTAL (WRITTEN OUT)		OOLLARS
	\$	\$	
F.	Alternate bid #5: additional cost Maximum Price)	st to install base bid type A1 and B1 lights during a night shift. (Gua	aranteed
	6. TOTAL (WRITTEN OUT)		OOLLARS
	\$	\$	
G.	Maximum Price)	st to install base bid type A2 and B2 lights during a night shift. (Gua	
	7. TOTAL (WRITTEN OUT)		OOLLARS
	\$	\$	
н.	Alternate bid #7: additional cost Maximum Price)	st to install base bid type A3 and B3 lights during a night shift. (Gua	aranteed
	8. TOTAL (WRITTEN OUT)		OOLLARS
	•	\$	



BIDDERS ARE TO ACKNOWLEDGE RECEIPT OF ADDENDUM #1.

PLEASE FAX BACK TO WAUKEGAN PARK DISTRICT, PARKS DEPARTMENT AT 847-244-7345 OR EMAIL TO tgirmscheid@waukeganparks.org. ALSO, PLEASE INCLUDE AN EXECUTED COPY OF THIS ADDENDUM AND NOTE RECEIPT OF THIS ADDENDUM IN YOUR BID PROPOSAL.

ADDENDUM #1 RECEIVED:				
SIGNED:				
DATE:				
COMPANY:				
Thank you				