

WAUKEGAN PARK DISTRICT

BID ADDENDUM #1

To: All Bidders

From: Tim Girmscheid, Manager of Planning Services

Re: Addendum #1

2019 Hinkston Pavilion Sewer Line

Bids Due on Thursday, December 19, 2019 at 11:00 a.m.

Date: December 13, 2019

PLEASE MAKE NOTE OF THE CHANGES AND CLARIFICATIONS:

1. Trench backfill within Grandville Avenue shall be CLSM (Controlled low strength material)
2. All spoils stay on site and shall be evenly spread over trench
3. Directional boring alternates will be considered. Alternate price and which sections of sewer line to be directionally bored must be indicated in your proposal on the bottom of Bid Package Page 26 of 49.
4. Owner will disconnect all electrical.
5. Asphalt work will be by owner. Base to be prepared by contractor per specifications.
6. Pump and above ground piping are to be removed from pit.
7. Existing PVC vent pipe to be cut and capped within 1' of the ceiling.
8. At least one electric and one water line are presumed to be in the gravel bed where sewer line connection and clean out are to be installed. Hand digging is expected.

End of Addendum #1

BIDDERS ARE TO ACKNOWLEDGE RECEIPT OF ADDENDUM #1.

PLEASE FAX BACK TO WAUKEGAN PARK DISTRICT, PARKS DEPARTMENT AT 847-244-7345 OR EMAIL TO TGIRMSCHIED@WAUKEGANPARKS.ORG. ALSO, PLEASE INCLUDE AN EXECUTED COPY OF THIS ADDENDUM AND NOTE RECEIPT OF THIS ADDENDUM IN YOUR BID PROPOSAL.

ADDENDUM #1 RECEIVED:

SIGNED: _____

DATE: _____

COMPANY: _____

Thank you.