

WAUKEGAN PARK DISTRICT

BID ADDENDUM #1

To: All Bidders

From: Tim Girmscheid, Manager of Planning Services

Re: Addendum #1

2023 HOME DEMOLITION AT 542 S. MCALISTER
Bids Due on **MONDAY, OCTOBER 16, 2023 AT 10:15 AM**

Date: **OCTOBER 12, 2023**

PLEASE MAKE NOTE OF THE CHANGES AND CLARIFICATIONS:

1. Clarifications:

- A. All known Asbestos Containing Materials have been removed so no abatement is necessary.**
- B. There is no Air Conditioner in home, so no coolant evacuation is needed.**
- C. The Contractor is responsible for and covers all costs associated with utility disconnects. The water line must be terminated at the main which according to the City of Waukegan Water Meter Department is located under McAlister Ave approximately 2'-4' from western curb. The sewer main is located under McAlister Ave but can be terminated and plugged in the parkway.**

End of Addendum #1

BIDDERS ARE TO ACKNOWLEDGE RECEIPT OF ADDENDUM #1.
PLEASE INCLUDE AN EXECUTED COPY OF THIS ADDENDUM AND NOTE RECEIPT OF THIS ADDENDUM IN YOUR BID PROPOSAL.

ADDENDUM #1 RECEIVED:

SIGNED: _____

DATE: _____

COMPANY: _____

Thank you.